

RTU2020 Assemblies

Model Selection Guide

MODEL NUMBER	SPECIFICATIONS
HARDWARE	
SC-UCMX01 ¹	RTU2020 Controller, 28 Mixed I/O
Note 1 – i) Analog Input (HART) 8, Analog Output (HART) 2, Digital Input 10, Pulse Input (High Speed) or Digital Input 2, □ Digital Output 6	

SOFTWARE	
SP-EBLDR1 ²	RTU Builder (per client, unlimited IO, RTU)
SP-RTU101 ³	RTU Builder R100 Media and Documentation
SP-IHARTP ⁴	HART support for SC-UCMX01
SP-MCALC1 ⁵	Gas & Liquid Calculation Library
<p><u>All software orders require a Siebel ID and a completed SW order form when placing the order.</u></p> <p>Note 2 – One required for each computer (physical or virtual) RTU Builder is to be installed on. Can run both online and offline.</p> <p>Note 3 – One required for one or multiple copies of SP-EBLDR1</p> <p>Note 4 – HART enabler license required (one for one unit) where HART digital access is required</p> <p>Note 5 - Includes AGA3, AGA5, AGA7, AGA8, AGA9, AGA11 function blocks</p>	

Distributed by:



888.858.3647 | relevantsolutions.com